



Product Service

Attestation of Conformity

No. N8A 18 04 95688 172

Holder of Certificate: LEDVANCE GmbHSteinerne Furt 62
86167 Augsburg
GERMANY**Product:**Flood lights
(FLOODLIGHT 100DEG SENSOR)**Model(s):**FLOOD 20W/3000K BK 100DEG S;
FLOOD 20W/4000K BK 100DEG S;
FLOOD 50W/3000K BK 100DEG S;
FLOOD 50W/4000K BK 100DEG S**Parameters:**

Rated Voltage :	220-240VAC
Rated Frequency :	50/60Hz
Rated Power :	20W [FLOOD 20W/3000K BK 100DEG S; FLOOD 20W/4000K BK 100DEG S]; 50W [FLOOD 50W/3000K BK 100DEG S; FLOOD 50W/4000K BK 100DEG S]
Protection Class :	I
Degree of Protection :	IP65
Blue Light Risk Group :	RG1
ta :	50°C

Tested according to:EN 60598-2-5:2015
EN 60598-2-24:2013
EN 60598-1:2015
EN 62493:2015

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

6814018016701

Date, 2018-04-19

(Taylor Yao)



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1